

Major Sanitary Sewer Overflows

SRCS D Interceptor System - Major SSOs (2005-2009)			
Year	No. of Interceptor System SSO	Description of SSO	Volume (1,000's gal.)
2005*	2	Outlet Siphon structure located on Mira Del Rio Street overflowed	10,077
		Maintenance hole located at the intersection of Fruitridge and Florin Perkins Roads overflowed	560
2006	0	n/a	n/a
2007	0	n/a	n/a
2008	1	One spill occurred on January 4, 2008 on Freeport Boulevard during a major storm.	54
2009	0	n/a	n/a

* On December 31, 2005 the Sacramento region experienced a very large winter storm with over 3 inches of rain falling in a 24 hour period. As a result of this storm the Sacramento Regional County Sanitation District (SRCS D) had two Sanitary Sewer Overflows (SSOs) within the Interceptor System. The two SSOs are listed above in the table.